



FIRE DEPARTMENT SANTA CLARA COUNTY

14700 Winchester Blvd., Los Gatos, CA. 95032-1818
(408) 378-4010 • (408) 378-9342 (fax) • www.sccfd.org



STANDARD DETAILS & SPECIFICATIONS	Spec No	<u>SP-5</u>
	Rev. Date	<u>08/03/10</u>
	Eff. Date	<u>03/05/99</u>
	Approved By	_____
	Page <u>1</u>	of <u>1</u>

SUBJECT: Specifications for the design and installation of fire sprinkler systems in multi-unit residential buildings.

SCOPE

This standard applies to the installation of automatic fire sprinkler systems that are required by local ordinance for multi-unit residential buildings, up to and including, four (4) stories in height when National Fire Protection Standard (NFPA) #13R is used as the design basis.

Note: In accordance with the California Building Code (CBC), a NFPA 13R design cannot be used when sprinklers are used to substitute for 1-hour construction, or for increases in building height or allowable area as protection is not provided throughout the building.

REQUIREMENTS

The installation and design of the system shall comply with chapter 9 of the CBC (Title 24, Part 2), and the provisions of NFPA Standard 13R, except as modified herein.

Location of Sprinklers

Fire sprinklers shall be installed in accordance with their listing, shall protect all usable spaces including, but not limited to:

- Penthouses
- Equipment rooms
- Elevator shafts
- Service chutes (dumbwaiter, laundry, etc.)
- Underneath combustible exterior stairs
- Porte Cochere
- Patios, porches, balconies and stairs having overhead exterior wall projections greater than 6 inches in depth

Monitoring

Automatic fire sprinkler systems shall be monitored in accordance with the California Fire Code.

Annunciation

Systems installed within buildings equipped with approved fire alarm systems, shall be annunciated by floor and/or zone at the fire alarm panel (and remote annunciator if one exists). The designer shall incorporate equipment and devices as necessary to achieve the required annunciation.

Fire Department Connections

Fire department connections shall be provided as part of the system and be located proximal to the public way, on the primary entry side of the building.

SD&S SP5 Sprinkler Install MultiFamily/DM:dh/08/03/10